



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Johns Manville Corporation
717 17th Street
Denver, CO 80202

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: JM TPO Single Ply Roof Systems over Wood Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This new NOA consists of pages 1 through 8.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 14-0627.05
Expiration Date: 09/29/21
Approval Date: 09/29/16
Page 1 of 8

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Single Ply
Materials:	TPO
Deck Type:	Wood
Maximum Design Pressure:	-112.5 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
JM TPO 45	45 mils thick	ASTM D6878 TAS 131	Polyester reinforced Thermoplastic Olefin single ply membrane.
JM TPO 60	60 mils thick	ASTM D6878 TAS 131	Polyester reinforced Thermoplastic Olefin single ply membrane.
JM TPO 80	80 mils thick	ASTM D6878 TAS 131	Polyester reinforced Thermoplastic Olefin single ply membrane.
JM TPO Walkpad	5/32" x 30" x 50'	Proprietary	Textured walkway protection membrane
JM TPO Detail Membrane	24" x 50'	TAS 131	Non-reinforced membrane for wrapping pipe flashings and vertical stacks and for waterproofing joints of JM TPO Coated Metal.
JM TPO Universal Corners	Various	TAS 131	Pre-molded for easy installation of curb flashings or corner flashings on JM TPO-Coated Metal or JM TPO Membrane.
JM TPO T-Joint Patch	4"	TAS 131	Non-reinforced membrane patch for covering t-joints and/or discs and fasteners.
JM TPO Pipe Boots	1" x 6"	TAS 131	Cone-shaped stepping boots designed for flashing pipe penetrations.
JM TPO Peel & Stick Pipe Boots	1" x 6"	TAS 131	Cone-shaped stepping boots designed for flashing pipe penetrations.
JM TPO Split Pipe Boot	Various	TAS 131	Cone shaped stepping boots designed for flashing pipe penetrations.
JM Square Pipe Boots	2" x 8" & 4" x 8"	TAS 131	Square shaped stepping boots designed for flashing pipe penetrations.
JM TPO Cover Tape	6" x 100'	TAS 131	30 mil membrane with a factory-applied peel and stick adhesive tape used to strip in metal flanges.
JM TPO 10" Cover Tape	10" x 100'	TAS 131	30 mil membrane with a factory-applied peel and stick adhesive tape used to strip in metal flanges.
JM TPO Penetration Pocket	7.5" x 6"	TAS 131	Two-piece molded pocket with a rigid vertical wall and preformed flanges.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
JM TPO Coated Metal	4' x 10'	TAS 131	JM TPO Membrane laminated onto galvanized steel.
JM TPO Peel & Stick 6" RTS	6" x 100'	TAS 131	45 mil TPO membrane strip with a 3" tape factory laminated along one edge.
JM TPO Peel & Stick 10" RPS	10" x 100'	TAS 131	45 mil TPO membrane strip with a 3" tape factory laminated along one edge.
JM TPO Curb Flashing	18" x 50'	TAS 131	60 mil TPO membrane for flashing curbs and parapet walls.
JM TPO Reinforced Cover Strip	8" x 50'	TAS 131	60 mil TPO membrane strip use as a heat-weldable strip in mechanically fastened systems

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI	Isocyanurate Insulation.	Johns Manville
ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI	Isocyanurate Insulation with glass reinforced facers	Johns Manville
ENRGY 3 FR, ENRGY 3 FR 25 PSI	Isocyanurate Insulation with inorganic coated glass reinforced facers; bottom face is premium coated for combustible decks.	Johns Manville
Invinsa Roof Board	High density polyisocyanurate board	Johns Manville
Invinsa FR Roof Board	Flame-resistant, High density polyisocyanurate board.	Johns Manville
JM SECUROCK Gypsum-Fiber Roof Board	Rigid, gypsum-based board stock	Johns Manville



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	All Purpose Fasteners	Truss head, self-drilling fastener for wood, steel, and concrete decks.	#14 x 16” max.	Johns Manville
2.	JM TPO RhinoPlate	Membrane bonding plate	3” round	Johns Manville
3.	High Load Fasteners	Insulation and membrane fastener for steel, wood, and concrete decks.	#15 x 14” max.	Johns Manville
4.	High Load Plate	Seam plate with reinforcing ribs and eyehooks	2-3/8” round steel plate	Johns Manville

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Momentum Technologies, Inc.	RX10A8A	TAS 131	03/29/10
	RX14C8A	TAS 131	03/29/10
	RX10A8B	TAS 131	03/29/10
PRI Construction Materials Technologies, LLC.	JMC-186-02-01.1	TAS 131	09/19/14
	JMC-186-02-02.1	TAS 131	10/10/14
	JMC-201-02-01B	TAS 114 J	07/10/14
UL, LLC	R10167	UL 790	09/06/16
Trinity ERD	J33600.08.13	TAS 131	08/09/13



Membrane Type: TPO

Deck Type II: Wood, Insulated

Deck Description: Min. 1⁵/₃₂" plywood or wood plank fastened a maximum 6" o.c with 0.113" ring shank nails to wood supports spaced a maximum 24" o.c.

System Type C(1): One or more layers of insulation simultaneously attached. Membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI Minimum 0.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI Minimum 0.5" thick	1 with 2	See below
Invinsa Roof Board, Invinsa FR Roof Board, or JM SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	1 with 2	See below

Note: Insulation shall be loose-laid and membrane mechanically fastened. See base sheet attachment below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: JM TPO (min. 60 mil) induction welded to JM TPO RhinoPlates which are fastened a maximum 24" o.c. through the deck into the wood supports with a minimum 1" embedment in rows spaced a maximum 24" o.c. . Side laps shall be a minimum 2.5" wide and are sealed with a minimum 1.5-inch wide heat weld.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7).



Membrane Type: TPO

Deck Type II: Wood, Insulated

Deck Description: Min. ¹⁵/₃₂" plywood or wood plank fastened a maximum 6" o.c with 0.113" ring shank nails to wood supports spaced a maximum 24" o.c.

System Type C(2): One or more layers of insulation simultaneously attached. Membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI Minimum 0.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI Minimum 0.5" thick	1 with 2	See below
Invinsa Roof Board, Invinsa FR Roof Board, or JM SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	1 with 2	See below

Note: Insulation shall be loose-laid and membrane mechanically fastened. See base sheet attachment below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: JM TPO (min. 60 mil) induction welded to JM TPO RhinoPlates using the following patterns:

Option #1: JM TPO RhinoPlates and All Purpose Fasteners are secured a maximum 6" o.c. through the deck into the wood supports with a minimum 1" embedment in rows spaced a maximum 48" o.c. Side laps shall be a minimum 2.5" wide and are sealed with a minimum 1.5-inch wide heat weld.
(Maximum Design Pressure: -112.5 psf. (See General Limitation #7))

Option #2: JM TPO RhinoPlates and All Purpose Fasteners are secured a maximum 9" o.c. through the deck into the wood supports with a minimum 1" embedment in rows spaced a maximum 48" o.c. Side laps shall be a minimum 2.5" wide and are sealed with a minimum 1.5-inch wide heat weld.
(Maximum Design Pressure: -60 psf. (See General Limitation #7))

Maximum Design Pressure: See options above.



Membrane Type: TPO

Deck Type II: Wood, Insulated

Deck Description: Min. 1 9/32" plywood or wood plank fastened a maximum 6" o.c with 0.113" ring shank nails to wood supports spaced a maximum 24" o.c.

System Type D: All layers of insulation simultaneously mechanically fastened with base sheet

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following:

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI Minimum 0.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ENRGY 3 FR, ENRGY 3 FR 25 PSI Minimum 0.5" thick	N/A	N/A
Invinsa Roof Board, Invinsa FR Roof Board, or JM SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All layers of insulation and membrane shall be simultaneously attached. See membrane below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: JM TPO is mechanically attached using High Load Fasteners and High Load Plates spaced 6" o.c. within 6" wide laps, spaced 54" o.c. and sealed with minimum 1.5" wide heat welds.

Maximum Design Pressure: -60 psf. (See General Limitation #7).



WOOD DECK SYSTEM LIMITATIONS:

1. A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 14-0627.05
Expiration Date: 09/29/21
Approval Date: 09/29/16
Page 8 of 8